

**PORTABLE APPLIANCE TESTING
REPORT**

Sample Report

R. Langston Jones & Co. Ltd Station Street West Business Park Coventry CV6 5BP

SAMPLE

Portable Appliance Testing

Electrical Inspection & Testing

Load Profiling

Emergency Lighting

Thermal Imaging

Sample Report

R. Langston Jones & Co. Ltd Station Street West Business Park Coventry CV6 5BP

SAMPLE

PORTABLE APPLIANCE TESTING SUMMARY

<u>Test Date</u>	<u>No of Tests</u>	<u>Plugs Replaced</u>	<u>Fuses Changed</u>	<u>Re-Termination</u>	<u>No of Fails</u>
31/10/2005	29	2	1	1	2
Total	29	2	1	1	2

FAILED APPLIANCES REPORT

Sample Report

R. Langston Jones & Co. Ltd Station Street West Business Park Coventry CV6 5BP

Barcode	Description	Manufacturer	Location	Eng	Date	Vis	Pol	E Bond	Ins	Load	Lkge	Pass/Fail
90000006	DESK FAN	XPELAIR-TAURUS	MAIN OFFICE	SD	31/10/2005	F						Fail
				<i>DAMAGED ENCLOSURE/CASING/SWITCH/SOCKET</i>								
90000021	EXTENSION LEAD	MARBO	WORKSHOP	SD	31/10/2005	F						Fail
				<i>LEAD PERISHED/DAMAGED/WORN</i>								

PORTABLE APPLIANCE TESTING REPORT

Sample Report

R. Langston Jones & Co. Ltd Station Street West Business Park Coventry CV6 5BP

Barcode	Description	Manufacturer	Location	Eng	Date	Vis	Pol	E Bond	Ins	Load	Lkge	Pass/Fail
90000001	SCANNER	HEWLETT PACKARD	CONFERENCE RM	SD	31/10/2005	P		00.09 OHM P	>99.99 MEG P	<0.05 kVA P	0.40 mA P	Pass
90000002	OVERHEAD PROJECTOR <i>C - RE-TERMINATED</i>	ANDERS & KERN	CONFERENCE RM	SD	31/10/2005	P		00.18 OHM P	>99.99 MEG P	0.31 kVA P	<0.10 mA P	Pass
90000003	TELEVISION / VIDEO	AMSTRAD	CONFERENCE RM	SD	31/10/2005	P			>99.99 MEG P	<0.05 kVA P	<0.10 mA P	Pass
90000004	DESK FAN	XPELAIR-TAURUS	MAIN OFFICE	SD	31/10/2005	P			>99.99 MEG P	<0.05 kVA P	<0.10 mA P	Pass
90000005	EQUIPMENT LEAD	VOLEX	MAIN OFFICE	SD	31/10/2005	P	P	00.07 OHM P	>99.99 MEG P			Pass
90000006	DESK FAN	XPELAIR-TAURUS	MAIN OFFICE	SD	31/10/2005	F		<i>DAMAGED ENCLOSURE/CASING/SWITCH/SOCKET</i>				Fail
90000007	EQUIPMENT LEAD <i>B - FUSE REPLACED</i>	PENCON	MAIN OFFICE	SD	31/10/2005	P	P	00.08 OHM P	>99.99 MEG P			Pass
90000008	EQUIPMENT LEAD	I-SHENG	MAIN OFFICE	SD	31/10/2005	P	P	00.07 OHM P	>99.99 MEG P			Pass
90000009	DESK FAN	XPELAIR-TAURUS	MAIN OFFICE	SD	31/10/2005	P			>99.99 MEG P	0.06 kVA P	<0.10 mA P	Pass
90000010	EQUIPMENT LEAD	SHINAGAWA	MAIN OFFICE	SD	31/10/2005	P	P	00.09 OHM P	>99.99 MEG P			Pass
90000011	PHOTOCOPIER	TOSHIBA	MAIN OFFICE	SD	31/10/2005	P		00.08 OHM P	>99.99 MEG P			Pass
90000012	MONITOR	DELL	MAIN OFFICE	SD	31/10/2005	P		00.12 OHM P	>99.99 MEG P	<0.05 kVA P	0.49 mA P	Pass
90000013	PERSONAL COMPUTER	DELL	MAIN OFFICE	SD	31/10/2005	P		00.11 OHM P	>99.99 MEG P	<0.05 kVA P	<0.10 mA P	Pass
90000014	DESK FAN	XPELAIR	MAIN OFFICE	SD	31/10/2005	P			>99.99 MEG P	0.06 kVA P	<0.10 mA P	Pass
90000015	EXTENSION LEAD	DURA PLUG	MAIN OFFICE	SD	31/10/2005	P		00.16 OHM P	>99.99 MEG P			Pass

PORTABLE APPLIANCE TESTING REPORT

Sample Report

R. Langston Jones & Co. Ltd Station Street West Business Park Coventry CV6 5BP

Barcode	Description	Manufacturer	Location	Eng	Date	Vis	Pol	E Bond	Ins	Load	Lkge	Pass/Fail				
90000016	EQUIPMENT LEAD	PENCON	WORKSHOP	SD	31/10/2005	P	P	00.08 OHM	P	>99.99 MEG	P	Pass				
90000017	HEAT BOND IRON	HULME MARTIN	WORKSHOP	SD	31/10/2005	P		00.08 OHM	P	>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000018	DESK LAMP A - PLUG REPLACED	1001	WORKSHOP	SD	31/10/2005	P		00.09 OHM	P	>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000019	PRESSURE INDICATOR	NO MANUFACTURER NAME	WORKSHOP	SD	31/10/2005	P		00.11 OHM	P	>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000020	POWERTOOL/WORKSHOP EQUIP A - PLUG REPLACED	EDWARDS	WORKSHOP	SD	31/10/2005	P		00.09 OHM	P	>99.99 MEG	P	0.75 kVA	P	<0.10 mA	P	Pass
90000021	EXTENSION LEAD	MARBO	WORKSHOP	SD	31/10/2005	F		<i>LEAD PERISHED/DAMAGED/WORN</i>							Fail	
90000022	DESK FAN	EXPELAIR TAURUS	WORKSHOP	SD	31/10/2005	P				>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000023	DESK LIGHTING	ANGLEPOISE	WORKSHOP	SD	31/10/2005	P				>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000024	ISOLATION TRANSFORMER	NO MANUFACTURER NAME	WORKSHOP	SD	31/10/2005	P		00.07 OHM	P	>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000025	DESK LAMP	ANGLEPOISE	WORKSHOP	SD	31/10/2005	P				>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000026	DEMAGNETISER	ECLIPSE	WORKSHOP	SD	31/10/2005	P		00.11 OHM	P	>99.99 MEG	P	0.36 kVA	P	<0.10 mA	P	Pass
90000027	ENGRAVER	DREMEL	WORKSHOP	SD	31/10/2005	P				>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000028	MICROWAVE OVEN	PANASONIC	KITCHEN	SD	31/10/2005	P		00.08 OHM	P	>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass
90000029	KETTLE	SWAN	KITCHEN	SD	31/10/2005	P		00.07 OHM	P	>99.99 MEG	P	<0.05 kVA	P	<0.10 mA	P	Pass